Energy Performance Certificate

HM Government

16, Beech Grove, Princes Road, HULL, HU5 2QY

Dwelling type:	Mid-terrace house			
Date of assessment:	14	September	2017	
Date of certificate:	14	September	2017	

Reference number: Type of assessment: Total floor area:

9648-2019-7201-5133-9924 RdSAP, existing dwelling 83 m²


Use this document to:

- Compare current ratings of properties to see which properties are more energy efficient
- Find out how you can save energy and money by installing improvement measures

Estimated energy costs of dwelling for 3 years:			£ 3,231		
Over 3 years you could save			£ 1,005		
Estimated energy costs of this home					
	Current costs	Potential costs	Potential future savings		
Lighting	£ 165 over 3 years	£ 165 over 3 years			
Heating	£ 2,733 over 3 years	£ 1,839 over 3 years	You could		
Hot Water	£ 333 over 3 years	£ 222 over 3 years	save £ 1,005		
Totals	£ 3,231	£ 2,226	over 3 years		

These figures show how much the average household would spend in this property for heating, lighting and hot water and is not based on energy used by individual households. This excludes energy use for running appliances like TVs, computers and cookers, and electricity generated by microgeneration.

Energy Efficiency Rating



The graph shows the current energy efficiency of your home.

The higher the rating the lower your fuel bills are likely to be.

The potential rating shows the effect of undertaking the recommendations on page 3.

The average energy efficiency rating for a dwelling in England and Wales is band D (rating 60).

The EPC rating shown here is based on standard assumptions about occupancy and energy use and may not reflect how energy is consumed by individual occupants.

Top actions you can take to save money and make your home more efficient

Recommended measures	Indicative cost	Typical savings over 3 years	Available with Green Deal
1 Room-in-roof insulation	£1,500 - £2,700	£ 585	\bigcirc
2 Internal or external wall insulation	£4,000 - £14,000	£ 195	S
3 Heating controls (room thermostat)	£350 - £450	£ 114	\bigcirc

See page 3 for a full list of recommendations for this property.

To find out more about the recommended measures and other actions you could take today to save money, visit www.gov.uk/energy-grants-calculator or call **0300 123 1234** (standard national rate). The Green Deal may enable you to make your home warmer and cheaper to run.